

CITY OF BALTIMORE WET WEATHER CONSENT DECREE SMOKE AND DYED WATER TESTING FORM		Page <u>1</u> of <u>2</u>
Sewershed: Dundalk	Consultant: RJN Group, Inc.	Date: YYYYMMDD <u>2008/10/31</u>
Test to be performed: Smoke <u> </u> Dye <u>✓</u>	Ground Condition: Dry <u>✓</u> Damp <u> </u> Wet <u> </u>	Supervisor initials: <u>TS</u>
Manhole ID: <u>S69A1 010.MH</u>	Test ID: <u>D1047-139</u>	Notifications - made daily: <u>✓</u> (Residents, Fire, 311)

Field Sketch: Show all manholes with numbers, blower placement location, sandbag or isolation device location, street names, building addresses and locations, defect locations and photograph numbers.

Van Daman St

Beckley St

S69A1
010

↓

S69A1
006


N

←

5 min 10 gal
Dye trace + Flood
man hole frame
and walls leaking
75 sq Ft DA
P

N

↓



CITY OF BALTIMORE WET WEATHER CONSENT DECREE SMOKE AND DYED WATER TESTING FORM		Page <u>1</u> of <u>2</u>
Sewershed: Dundalk	Consultant: RJN Group, Inc.	Date: YYYYMMDD <u>2008/10/31</u>
Test to be performed: Smoke <u> </u> Dye <u>✓</u>	Ground Condition: Dry <u>✓</u> Damp <u> </u> Wet <u> </u>	Supervisor initials: <u>TS</u>
Manhole ID: <u>S69A1_010MH</u>	Test ID: <u>D1047-139</u>	Notifications - made daily: <u>✓</u> (Residents, Fire, 311)
Field Sketch: Show all manholes with numbers, blower placement location, sandbag or isolation device location, street names, building addresses and locations, defect locations and photograph numbers.		



D1047-139-OB01-P01



D1047-139-OB01-P02



D1047-139-OB01-P03